



<b>Property Information</b>		<b>Contractor or Licensed Owner Information</b>
Building Name		Name
Address		Job #
City		

**ANNUAL INSPECTION, TESTING, AND MAINTENANCE**  
*Include ALL Quarterly Inspections*

I = Inspection    T = Test    M = Maintenance                      P = Pass    F = Fail    N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.19	I	Sprinklers	5.2.1			
1.20	I	Buildings (Freeze Protection)	4.1.1.1		<b>Owner's Responsibility</b>	
1.21	I	Pipe and Fittings	5.2.2			
1.22	I	Hangers	5.2.3			
1.23	I	Seismic Braces	5.2.3			
2.1	T	Field Service Test Required <i>(Send Report to Fire Code Official)</i>	5.3.1		If REQUIRED, Enter 'F' until results are returned from Lab	
2.2	T	Recalled Sprinklers <i>If not present = Pass; If present = Fail</i>	Title 19 904.1(c)			
2.3	T	Water Flow Alarm Devices <i>90 sec. maximum - (Enter Time )</i>	5.3.3 13.2.6		sec.	
2.4	T	Main Drain Test <i>(Enter Data on Page 1 of this Form)</i>	13.2.5 13.3.3.4			
2.5	T	Control Valve - Position	13.3.3.2			
2.6	T	Control Valve – Operation	13.3.3.1			
2.7	T	Supervisory Devices	13.3.3.5			
2.8	T	Backflow Preventer Assemblies	13.6.2			
2.9	T	Small Hose Connections* <i>w/PRV Hose Valves – Partial Flow Test</i>	13.5.2.3 13.5.3.3			
2.10	T	PRV – Fire Sprinkler Systems	13.5.1.3			
3.1	M	Control Valves	13.3.4			
3.2	M	Small Hose Connections*	13.5.6.3			
3.3	M	Obstruction Investigation required <i>(If "Yes", see Deficiencies and Comments Section for Results.)</i>	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.4	M	System Returned to Service	4.5.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	

\* Small hose connections are hose valves and optional hose supplied by the fire sprinkler system. They do not include Class I, II, or III standpipe systems.

**D = Deficiency    C = Comment    (Indicate type)**

Item	Date	Riser	D	C	Deficiencies and Comments <i>Indicate all equipment, devices and parts that were repaired or replaced</i>

